

Current roof leaks:

Gym (not marked locations)

Mainspace, near couch area, other unmarked locations.

Pics w/captions:



Visible cracking on much of roof, even from far away.



Top roof downspout drains to lower roof, possible to direct to drain outside building?



Some areas would benefit from regular leaf/debris cleaning



Cracking, cleaning, and vent pipes need covers.





Cracking, cleaning, and vent pipes need covers.



Cracking, cleaning, and vent pipes need covers.





Pipes that could be covered.

